QUESTIONS ESTERO MUNICIPAL IMPROVEMENT DISTRICT WATER MAIN CONDITION ASSESSMENT (CIP 405-723)

Questions as of 11.14.2024			
	Question	Response	
1	Exhibit A – Testing Port As-Builts and Exhibit B – Transmission Line Alignment were not included in the RFP. Are they available?	Attachments have been uploaded to the RFP Page	
2	Is all of the alignment in paved areas?	Most of the alignment is in or adjacent to paved areas, please see Exhibit B for more information.	
3	What is the depth of the pipe?	Please see Exhibit B for depth of pipe at selected test locations.	
4	Is water expected in excavations?	Foster City has a high water table, so water should be expected in areas located within the City.	
5	The RFP states, The consultant will perform (or employ professionals to perform) the chosen tests, surveys, and inspections and prepare a final report that summarizes the findings and identifies pipe locations that may be experiencing leaks, wall thinning, coating thinning or spalling, and/or corrosion. Is the cost proposal to include the costs of the professionals performing the testing?	Yes, the cost proposal should include the costs of professionals performing testing.	

Include in Addendum?		